WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85049
Permit No.
Basin 71

NOTICE OF INTENT NO. 47373

1. OWNER Dave Bernosky
MAILING ADDRESS 9575 Alice Lane
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 9575 Alice Lane

2. LOCATION SW 1/4 ____ 1/4 Sec. 30 T 35N N/S R 38E E Humboldt County
PERMIT NO. ____ Issued by Water Resources | 10-543-01 Parcel No. | Subdivision Name

**3. WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other ____

**4. PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

**5. WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other ____

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| sand & gravel | | 198 | | |
| w/intermediate clay | | | | |
| stringers | | | 258 | 60 |

Date started 10/27/01 , 19__
Date completed 10/27/01 , 19__

**7. WELL TEST DATA**

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | | 3 hrs. |

**8. WELL CONSTRUCTION**
Depth Drilled 258 Feet Depth Cased 258 Feet

**HOLE DIAMETER (BIT SIZE)**

| | From | To |
|---|---|---|
| 8 Inches | 198 Feet | 258 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6.625 | | .188 | 198 | 258 |
| | | | | |
| | | | | |

**Perforations:**
Type perforation mill slot
Size perforation 1/8 x 3
From 198 feet to 258 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal ____
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

**9. WATER LEVEL**
Static water level 198 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1875

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 11/1/01