WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85055
Permit No.
Basin 87

NOTICE OF INTENT NO. 47498

1. OWNER Glen Owen
MAILING ADDRESS 3405 Quilici
Reno, NV 89511

ADDRESS AT WELL LOCATION 3405 Quilici

2. LOCATION NE 1/4 NW 1/4 Sec. 13 T 18N N/S R 19E E Washoe County
PERMIT NO. WL010212 (Issued by Water Resources) 040-730-30 (Parcel No.)
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented Cobblels		o	10	10
Cemented Gravels		10	25	15
Sand & Gravel		25	35	10
Cemented Gravel		35	60	25
Cemented Cobblels		60	68	8
Sand & Gravels		68	125	57
Red & Black Volcanic Rock		125	260	135
Volcanic Cobbels & Gravel		260	265	5
Brown Clay		265	273	8
Red & Black Volcanic Rock		273	303	30
Red Cinder		303	353	50

Date started 10/31/2001, 19__
Date completed 11/7/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100 +		2 HRS.

8. WELL CONSTRUCTION
Depth Drilled 353 Feet Depth Cased 353 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	285	Feet
9 7/8	Inches	285	Feet	353	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	353

Perforations:
Type perforation Well Screen
Size perforation .020
From 117 feet to 137 feet
From 293 feet to 333 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100' feet to 353' feet

9. WATER LEVEL
Static water level 24' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/12/2001

USE ADDITIONAL SHEETS IF NECESSARY