

OFFICE USE ONLY
 Log No. 850617
 Permit No. 108
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47451

1. OWNER Donc Little ADDRESS AT WELL LOCATION 16.5 Miller Lane
 MAILING ADDRESS Yerington, Nevada
 2. LOCATION NE 1/4 SW 1/4 Sec. 26 T. 14 N/S R. 25 E. County _____
 PERMIT NO. 14-241-41 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other well

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gray Clay</u>		<u>0</u>	<u>16</u>	
<u>Coarse Sand Fine</u>		<u>16</u>	<u>49</u>	
<u>Tan Clay</u>		<u>49</u>	<u>50</u>	
<u>Fine Sand Coarse</u>		<u>50</u>	<u>109</u>	
<u>Tan Clay</u>		<u>109</u>	<u>131</u>	
<u>Fine Sand</u>		<u>131</u>	<u>215</u>	
<u>Coarse Sand Gravel</u>	<input checked="" type="checkbox"/>	<u>215</u>	<u>240</u>	

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 235 Feet
 HOLE DIAMETER (BIT SIZE)
 From 16 5/8 Inches To 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>71</u>	<u>70</u>
<u>16 5/8</u>	<u>3.00</u>	<u>5/16</u>	<u>70</u>	<u>240</u>

Perforations:
 Type perforation Scill saw
 Size perforation 1 1/4 x 5/16 long staves
 From 225 feet to 235 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 0-100 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 235 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 12-13 To 2001
 Date completed 12-17 To 2001

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>60 GPM</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Levi Dulligan Inc
 Address Po Box 599
Silver Springs NV. 89429
 Nevada contractor's license number 00318411
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1877
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 12-17-01