

OFFICE USE ONLY
 Log No. 87075
 Permit No. _____
 Basin. 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47109

1. OWNER DON & CATHY LEVEN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 8300 Mesa Park Road Same
Reno, Nevada 89523
 2. LOCATION NW 1/4 SW 1/4 Sec 18 T. 19N N/S R. 19 E Washoe County
039-148-25 Mesa Park Area
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL ABANDONMENT/PLUGGING				
Static water level 129, total depth 206 feet				
7-26-01				
Attempt to pull casing (no movement)				
Perforate from 190 ft back to 50 feet,				
evidence of cement at 45 feet, perforator refusal				
Mix, pump & tremie 69 sack Type II Cement				
no return (extrem loss to formation)				
7-27-01				
Top of cement @56 feet, Static water level @51 feet				
Mix & pump 24 sacks of cement				
No return(extrem loss to formation)				
Let set for 3.5 hours				
Cement at 35 feet				
Mix & pour 8 sacks to fill to surface				
Excavate & cut casing below grade				
Equipment:				
Schramm T660 Drill				
Holt down hole perforator				
Grout pump and mixer				
Materials used:				
101 sack of Portland Type II Cement				
Location: 50 ft. Sof N corner/40 ft W of E border				
Date started <u>July 25, 2001</u> , 19____				
Date completed <u>July 27, 2001</u> , 19____				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Feet	Inches
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____

Size perforation _____

From	feet to	feet
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____

Placement Method: Pumped Poured

Gravel Packed: Yes No

From _____ feet to _____ feet

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level _____ feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor

Address P.O. BOX 12370 Contractor

RENO, NEVADA 89510

Nevada contractor's license number 0022549 issued by the State Contractor's Board.

Nevada driller's license number issued by the 923 Division of Water Resources the on-site driller.

Signed [Signature] Driller performing actual drilling on site or contractor

Date July 31, 2001