

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 850711
 Permit No. 0725
 Basin 87
 Page 1 of 2
 NOTICE OF INTENT NO. 47381

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Truckee Meadow Water Authority ADDRESS AT WELL LOCATION Mendive School - Vista
 MAILING ADDRESS P.O. Box 30013 Rd. - Sparks,
Reno, NV 89520 Nevada

2. LOCATION SE 1/4 SW 1/4 Sec. 35 T 20N N/S R 20E E Washoe County
 PERMIT NO. 67725 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	2	
sandy clay		2	24	22
sandy clay w/rocks		24	27	3
clay w/sand		27	29	2
clay		29	38	9
sand & gravel		38	41	3
clay		41	79	38
sandstone		79	81	2
volcanics		81	87	6
sandy clay		87	104	17
black sand w/rocks		104	130	26
clay		130	135	5
sand & gravel		135	139	4
clay w/sand		139	141	2
sand w/gravel		141	150	9
clay		150	162	12
clay w/sand		162	176	14
sand w/broken rock		176	181	5
sand		181	191	10
sand & little clay		191	195	4
sand & gravel		195	206	11
sand & gravel/few		206		
cobbles			209	3
clay		209	214	5
sand & gravel w/clay		214	218	4
clay		218	221	3

Continued on next page

8. WELL CONSTRUCTION
 Depth Drilled 451 Feet Depth Cased 440 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
24 Inches 0 Feet 60 Feet
18 Inches 60 Feet 451 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>20</u>		<u>.375</u>	<u>0</u>	<u>60</u>
<u>12.75</u>		<u>.375</u>	<u>0</u>	<u>440</u>

Perforations:
 Type perforation full flow Roscoe Moss 12.75 x .312
 Size perforation .080 slot
 From 240 feet to 280 feet
 From 300 feet to 420 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 451 feet

9. WATER LEVEL
 Static water level 21 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2177
 Signed Jean A. Jones
 By driller performing actual drilling on-site or contractor
 Date 1/5/02

Date started 12/6/01, 19____
 Date completed 12/21/01, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
P/L 232 ft	<u>265</u>	<u>211</u>	<u>24 hrs.</u>
<u>plugged by 116371</u>			

