

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44093

1. OWNER Abenzo Pearce ADDRESS AT WELL LOCATION Hwy 95 A.N. Yerington NV 89447
MAILING ADDRESS #24 Hwy 95 A.N. Yerington NV 89447

2. LOCATION NE 1/4 NE 1/4 Sec. 16 T. 13 R. 25 E LYON County
PERMIT NO. 014-441-04 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	40	40
Packed Sands		40	64	24
Rock-Granite		64	66	2
Fractured Granite		66	74	8
De composed Granite		74	75	1
Granite		75	84	9
Fractured Granite		84	85	1
Granite		85	90	5
Fractures w/sand	x	90	97	7
Clay		97	110	13
Granite		110	112	2
Fractures w/sand	x	112	117	5
Clay		117	123	6
Granite		123	134	11
Fractures w/sand		134	138	4
Granite		138	146	8
Fractures w/sands		146	150	4
Clay		150	154	4

8. WELL CONSTRUCTION
Depth Drilled 154 Feet Depth Cased 154 Feet

HOLE DIAMETER (BIT SIZE)
From To
10 7/8 Inches 0 Feet 154 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.188</u>	<u>12</u>	<u>154</u>

Perforations:
Type perforation mill slot
Size perforation .125 x 3" x six rows
From 132 feet to 152 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 54' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 154 feet to 54 feet

9. WATER LEVEL
Static water level 28' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started Nov 22 2001, 19_____
Date completed Dec 10 2001, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			
Bail	40	12	4
Air lift	100	32	4
pump	20	10	4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Inland Pacific Drilling Co Inc Contractor
Address P.O. Box 831 Yerington NV 89447 Contractor
Nevada contractor's license number issued by the State Contractor's Board 36582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1958
Signed Joel W Brown By driller performing actual drilling on site or contractor
Date _____