

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47243

1. OWNER Jim Dye ADDRESS AT WELL LOCATION 2675 Leviathan Mine Road  
 MAILING ADDRESS 2675 Leviathan Mine Road Gardnerville Nv.  
Gardnerville, NV 89410

2. LOCATION SW 1/4 SW 1/4 Sec. 22 T 11N N/S R 21E E Douglas County  
 PERMIT NO. 0000-35-240-200 Doublesprings  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Andesite sluff	no	0	26	26
Redish brown clay	no	26	66	40
Hard Andesite	no	66	147	81
Brown Clay	no	147	162	15
Broken Andesite with clay seams	no	162	227	65
brown clay with some gravel seams	yes	227	268	41
sand and gravel with some clay seams	yes	268	292	24
brown clay	no	292	300	8

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  

<u>10 5/8</u> Inches	From <u>0</u> Feet	To <u>60</u> Feet
<u>9 7/8</u> Inches	From <u>60</u> Feet	To <u>300</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>300</u>

Perforations:  
 Type perforation factory Milled  
 Size perforation 3/16 X 3 6 row  
 From 260 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 188 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

Date started 10/3/2001, 19  
 Date completed 10/18/2001, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>2 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eddco Exploration Inc. Contractor  
 Address 7780 Curry Road Contractor  
Fallon, Nv, 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1588  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 10/22/2001