WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85173
Permit No.
Basin 104

NOTICE OF INTENT NO. 47244

1. OWNER Wesley Hamilton
MAILING ADDRESS 3300 Kings Canyon Rd.
Carson City,, NV 89703

ADDRESS AT WELL LOCATION 3300 Kings Canyon Rd.
Carson City, Nv.

2. LOCATION SE 1/4 SW 1/4 Sec. 13 T 15N N/S R 19E E Carson County
PERMIT NO. (Issued by Water Resources) 007-081-30 (Parcel No.) Kings Canyon (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Diorite Boulders and	no	0		
clay			67	67
Frctured Diorite	no	67	207	140
Fractured Diorite	yes	207	267	60
Brown gummy Clay	no	267	277	10
Broken Fractured	yes	277		
Diorite			300	23

Date started 10/23/2001, 19__
Date completed 11/9/2001, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		1 hr

8. **WELL CONSTRUCTION**
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	100	Feet
9 7/8	Inches	100	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	300

Perforations:
Type perforation Factory Milled
Size perforation 1/8 X 3 6 Row
From 240 feet to 260 feet
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100ft
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 100 feet to 300 feet

9. **WATER LEVEL**
Static water level feet below land surface
Artesian flow 4 G.P.M. 8 P.S.I.
Water temperature cold °F Quality good

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eddco Exploration Inc. (Contractor)
Address 7780 Curry Rd. (Contractor)
Fallon Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 11/18/2001

USE ADDITIONAL SHEETS IF NECESSARY