

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47765

1. OWNER Dean EVANS ADDRESS AT WELL LOCATION 2130 Fish Springs
 MAILING ADDRESS 1616 Hwy 395 Minden NV 89423 R.D. Minden NV 89423

2. LOCATION NW 1/4 NW 1/4 Sec. 6 T. 12 N/S R. 21 E. Douglas County
 PERMIT NO. 1221-06-001-010 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay</u>		<u>0</u>	<u>100</u>	<u>100 FT</u>
<u>Sand, gravel, clay</u>		<u>100</u>	<u>120</u>	<u>20 FT</u>
<u>Brown + gray clay</u>		<u>120</u>	<u>160</u>	<u>40 FT</u>
<u>Brown clay + sand and gravel</u>	<input checked="" type="checkbox"/>	<u>160</u>	<u>200</u>	<u>40 FT</u>

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 3/8 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	14	<u>1 8/8</u>	<u>+1</u>	<u>200</u>

Perforations:
 Type perforation factory milled
 Size perforation 3/32
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 200 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature 60A °F Quality clear

Date started 10-29-01
 Date completed 11-5-01

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>NA</u>	<u>2 Hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enke Drilling Co. Contractor
 Address Box 22372 Carson City NV 89721 Contractor
 Nevada contractor's license number 4739A issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11-5-01

RECEIVED
 0 NOV 16 AM 9:21
 STATE ENGINEER'S OFFICE