WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85222
Permit No.
Basin 76

NOTICE OF INTENT NO. 47271

1. OWNER Sierra West
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1920 Alta Vista Dr. Fernley, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 27 T. 20 N/S R 25 E Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 21-481-60 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Boulder		0	6	
Boulders Gravel		6	123	
Cemented Gravels little Clay		123	193	
Cemented Gravel		193	340	
Gravels Boulders	✓	340	440	
Boulders Gravels	✓	440	470	

RECEIVED 01 NOV 30 PM 1:10 STATE ENGINEER'S OFFICE

Date started 10-22 2001
Date completed 10-27 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		

8. WELL CONSTRUCTION
Depth Drilled 470 Feet Depth Cased 470 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
8 3/4 Inches	60 Feet	440 Feet
6 1/8 Inches	440 Feet	470 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15.00	3/16	+1	20
6 5/8	3.00	Sch 40	20	440
5"	9.00	3/16	430	470

Perforations:
Type perforation Scill Saw
Size perforation 1/4 x 6 Long 5 Rows
From 380 feet to 440 feet
From 450 feet to 470 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 440 feet

9. WATER LEVEL
Static water level 361 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc
Contractor
Address PO Box 599
Contractor
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature]
By driller performing actual drilling on site or contractor
Date 10-27-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

I