WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

**STATE OF NEVADA**
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85235
Permit No.
Basin 52

NOTICE OF INTENT NO. 4756

1. OWNER Union Pacific Railroad SP-13
MAILING ADDRESS 49 Stevenson Street, 15th Floor
San Francisco, CA 94015

ADDRESS AT WELL LOCATION 501 Hamilton Street,
Carlin, NV.

2. LOCATION NW 1/4 SE 1/4 Sec. 27 T 33N N/S R 52E E Elko County
PERMIT NO. Unknown (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

**3. WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

**4. PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

**5. WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| No state driller's report or as-built was available. | | | | |
| Abandoned by pumping neat cement via tremie from 14' to surface. Capped with 6" of concrete. | | | | |
| Quantities Used: | | | | |
| Concrete: 0.6 cu.ft. | | | | |
| Neat cement: 2.2 cu.ft. | | | | |

Date started 10/20/2001, 19__
Date completed 10/20/2001, 19__

**7. WELL TEST DATA**

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

**8. WELL CONSTRUCTION**
Depth Drilled ____ Feet Depth Cased 14.4 Feet

**HOLE DIAMETER (BIT SIZE)**

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

**Perforations:**
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

**9. WATER LEVEL**
Static water level 11.2 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039
Signed Derry Robblee (By driller performing actual drilling on-site or contractor)
Date 10/23/01

USE ADDITIONAL SHEETS IF NECESSARY

B.S.L.