WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85237
Permit No.
Basin 52

NOTICE OF INTENT NO. 41563

1. OWNER Union Pacific Railroad ICRW-4
MAILING ADDRESS 49 Stevenson Street, 15th Floor
San Francisco, CA 94015

ADDRESS AT WELL LOCATION 501 Hamilton Street,
Carlin, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 27 T 33N N/S R 52E E Elko County
PERMIT NO. Unknown (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Several construction details were not available prior to abandoning this well.				
Abandoned by pumping neat cement via tremie from 29' to surface. Surface stick-up was removed, and capped with 6" of concrete.				
Quantities Used:				
Concrete: 0.6 cu.ft. Neat cement: 19. cu.ft.				
Seal Type: Cement and bentonite grout.				

Date started 10/20/2001, 19__
Date completed 10/20/2001, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 29.5 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
20	Inches	0	Feet	20	Feet
18	Inches	20	Feet	29.5	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6			+1	29

Perforations:
Type perforation Slot
Size perforation 0.040"
From 9 feet to 29 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8.5'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8.5 feet to 29.5 feet

9. **WATER LEVEL**
Static water level 10.9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039
Signed Denny Rokkee (By driller performing actual drilling on-site or contractor)
Date 10/23/01

USE ADDITIONAL SHEETS IF NECESSARY

B.ST.L