WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85296
Permit No.
Basin 91

NOTICE OF INTENT NO. 38659

1. OWNER Greg and Debbie Schuster
MAILING ADDRESS 345 River Bend Rd.
Reno, NV 89439

ADDRESS AT WELL LOCATION 345 River Bend Rd.
Verdi, NV

2. LOCATION SW ¼ SE ¼ Sec. 15 T. 19 (N)/S R. 18 E. Washoe County
PERMIT NO. N/A (Issued by Water Resources) 038-654-02 (Parcel No.) Belli Ranch Estates (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	9	
Brown sand		9	13	
Brown Clay		13	18	
Sand & Gravel		18	21	
Brown Clay		21	23	
Boulders & Gravel		23	99	
Orange sandy clay		99	107	
Gray sandstone w/				
gray shale layers		107	150	
Lignite		150	173	
Green Clay		173	174	
Gray Shale		174	200	
Gray Sandstone		200	220	

Date started 7-6-01, 19
Date completed 7-23-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	75	215	4

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼" Inches		0 Feet	7 Feet
9 7/8" Inches		7 Feet	220 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	220

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 160 feet to 180 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100+
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 220 feet

9. WATER LEVEL
Static water level 107 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MILLER & SONS DRILLING CO. (Contractor)
Address P.O. Box 8056 Reno, NV 89507 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 8-18-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627