WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85258
Permit No.
Basin 100

NOTICE OF INTENT NO. 45440

1. OWNER Dennis Wills
MAILING ADDRESS P.O. Box 801 Minden Nev 89423
ADDRESS AT WELL LOCATION 3690 Quail Run Wellington Nev 89444

2. LOCATION S1/2 1/4 S1/2 1/4 Sec. 6 T. 10 N/S R. 22 E. Douglas County
PERMIT NO. (Issued by Water Resources) 1022-16-002-094 (Parcel No.) Pleasant Meadows (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvial Sand & Small Rock Top Soil		0	15	15
Small rock yellow Clay		15	37	22
Gravel	X	37	60	23
Fractured Rock & Yellow Clay		60	85	25
GRAVEL	X	85	120	35
Clay		120	132	12
Rock & Sharp gravel		132	140	8

Date started 8-30-01, 19
Date completed 9-21-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	15	4

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	135 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6/58		188	0	135

Perforations:
Type perforation Factory Saw Slott
Size perforation
From 105 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling (Contractor)
Address P.O. Box 92, Smith Nev 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23166A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date 9-24-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627