WASHOE #

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 85266
Permit No. [redacted]
Basin 83

NOTICE OF INTENT NO 43[redacted]60

1. OWNER **DP Operating** ADDRESS AT WELL LOCATION
MAILING ADDRESS **PO Box 838**
Poway CA

2. Location **SE** 1/4 **SE** 1/4 Sec **31** T **20N** R **22E** **Storey** County
PERMIT NO. 67/76 ~~W535~~ W535 PARCEL N0. **040-160-10** SUBDIVISION NAME

3. WORK PERFORMED
X New Well, Replace, Recondition, Deepen, Abandon, Other

4. PROPOSED USE
Domestic, Irrigation, Test, X Municipal/Industrial, Monitor, Stock

5. WELL TYPE
Cable, X Rotary, RVC, Air, Other, X Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG		0	65	65
				0
Hard granite.		65	178	113
				0
Black hard rock.		178	205	27
				0
Hard granite.		205	342	137
				0
Black hard rock.		342	380	38
				0
Hard granite.		380	433	47
				0
Black hard rock.		433	570	137
				0
Hard granite.		570	704	134
				0
Red volcanic.		704	830	126
				0
Black hard rock.		830	900	70
				0
				0
				0
				0
				0

RECEIVED 01 OCT 11 AM 11:49 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled **900** feet Depth Cased **900** feet

HOLE DIAMETER (BIT SIZE)

		From	To
24	inches	0 feet	900 feet
	~~inches~~	~~feet~~	~~feet~~
	inches	feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
16	42.05	250	+1 1/2	900

Perforations::
Type Perforation **Factory**
Size perforation **3/32 x 3"**
From **300** feet to **420** D feet
From **500** feet to **640** D feet
From **660** feet to **900** T feet
From feet to feet
From feet to feet

Surface Seal X YES No
Depth of Seal **100** feet
x Pumped
Poured
Gravel Packed: X Yes No
From **100** feet to **900** feet

Seal Type:
Neat Cement
x Cement Grout
Concrete Grout

9 WATER LEVEL
Static water level **97** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality

Date started **3-15** -01
Date completed **8-23** -01

7. WELL TEST DATA
TEST METHOD: Bailer Pump x Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **786**
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 9-10 -01