WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85270
Permit No.
Basin 89

NOTICE OF INTENT NO. 47501

1. OWNER Sanford Ward
MAILING ADDRESS 3719 22nd St
Lubbox, TX 79410

ADDRESS AT WELL LOCATION 2 Mill Station Ranch Rd.

2. LOCATION SE 1/4 SE 1/4 Sec. 22 T 16N N/S R 19E E Washoe County
PERMIT NO. WaCo#6928 (Issued by Water Resources) 055-200-45 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt & cobbles		0	7	7
San/clay		7	43	36
D.G.	x	43	331	288
Granite w/ fractures	x	331	457	126

Date started 7/20/2001, 19__
Date completed 7/28/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	30		4 hrs

8. WELL CONSTRUCTION
Depth Drilled 457 Feet Depth Cased 457 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	100	Feet
10 5/8	Inches	100	Feet	457	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	457

Perforations:
Type perforation Factory and Mechanical
Size perforation 3/32 x 3" and puncture

From 220 feet to 300 feet
From 357 feet to 377 feet
From 397 feet to 417 feet
From 437 feet to 457 feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 457 feet

9. WATER LEVEL
Static water level 117 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 8/1/01

USE ADDITIONAL SHEETS IF NECESSARY