WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85277
Permit No.
Basin 91

NOTICE OF INTENT NO. 44490

1. OWNER Robert Wise
MAILING ADDRESS 3380 Mario Rd.
Reno, NV 89523

ADDRESS AT WELL LOCATION 3380 Mario Rd.

2. LOCATION NW 1/4 ~~NNNE~~ 1/4 Sec. 22 T 19N N/S R 18E E Washoe County
PERMIT NO. WaCo#6832 Issued by Water Resources
038-682-11 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	6	6
Brown clay		6	14	8
Grey sandstone w/streaks of clay	x	14	237	223
Multicolored rounded rock	x	237	242	5

Date started 6/16/2001 , 19__
Date completed 6/20/2001 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	50		2 hrss

8. WELL CONSTRUCTION
Depth Drilled 242 Feet Depth Cased 242 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4"	Inches	0	Feet	100	Feet
10 5/8	Inches	100	Feet	242	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	242

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 182 feet to 202 feet
From 222 feet to 242 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 242 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 6/21/01

USE ADDITIONAL SHEETS IF NECESSARY