WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85283
Permit No.
Basin 81

NOTICE OF INTENT NO. 47518

1. OWNER Steve Hendricks
MAILING ADDRESS 3075 Holly Lane
Washoe Valley, NV 89704

ADDRESS AT WELL LOCATION 3075 Holly Lane

2. LOCATION SW 1/4 NW 1/4 Sec. 5 T 16N N/S R 20E E Washoe County
PERMIT NO. WC-WL#010176 (Issued by Water Resources) 050-450-16 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed Granite	x	113	132	19
Black & White Granite		132	155	23
Decomposed Granite with fractures	x	155	180	25
Black & White Granite		180	185	5
Decomposed Granite	x	185	188	3
Black & White Granite	x	188	220	32

Date started 9/6/2001, 19__
Date completed 9/7/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pumped	17	40	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	113	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	100	220

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 140 feet to 160 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Burn MacKay (By driller performing actual drilling on-site or contractor)
Date 9/7/01

USE ADDITIONAL SHEETS IF NECESSARY