

OFFICE USE ONLY
 Log No. 80293
 Permit No. _____
 Basin 94
 NOTICE OF INTENT NO. 47124

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SHIELA MACKIN ADDRESS AT WELL LOCATION 100 Britt Road
 MAILING ADDRESS 200 Britt Road Reno, Nevada 89506
 2. LOCATION NW 1/4 Sec 7 T 22N R 19 E Washoe County
 PERMIT NO. 079-382-23 Issued by Water Resources Parcel No. Red Rock estates #91 Parcel A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	16	15
Soft zone		16	18	2
Brown sandy clay		18	63	45
Soft zone (NO WATER)		63	69	6
Brown sandy clay		69	91	22
Soft zone (APP # GPM)	X	91	96	5
Brown sandy clay		96	140	44
Soft zone(app 5 GPM)	X	140	146	6
Brown sandy clay		146	198	52
Soft zone		198	203	5
Brown sandy clay		203	219	16
Soft zone	X	219	230	11
Brown sandy clay		230	235	5
Weathered granite		235	255	20
Soft weathered granite fracture	X	255	261	6
weathered granite		261	275	14

8. WELL CONSTRUCTION
 Depth Drilled 275 Feet Depth Cased 275 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 275 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	275

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 209 feet to 229 feet
 From 249 feet to 269 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 275 feet

Date started September 24, 2001, 19____
 Date completed September 25, 2001, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		

9. WATER LEVEL
 Static water level 67 feet below land surface
 Artesian flow _____ G.P.M. 45 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 923
 Signed [Signature]
 by driller performing actual drilling on site or contractor
 Date September 25, 2001