WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85301
Permit No.
Basin 207

NOTICE OF INTENT NO. 45799

1. OWNER Nevada Dept. of Transportation
MAILING ADDRESS 1263 South Stewart Street, Carson City, Nevada 89712

ADDRESS AT WELL LOCATION 29.5 Miles South of Lund M.P. 21 SR 318

2. LOCATION SW ¼ NE ¼ Sec. 21 T. 7 N/S R. 62 E. Nye County

Waiver M/O-1226 (Issued by Water Resources) | N/A (Parcel No.) | Hole No. 2 of 3 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvial gravel & boulders		0	5	5
Gravelly sand & silt		5	12	7
Gravel & sand		12	17	5
Clay & gravel		17	27	10
Brown clay		27	32	5
Clay & gravel		32	40	8
Clay & gravel with water bearing stringers	X	40	46	6
Clay & gravel		46	60	14

Date started October 23, 2001
Date completed October 25, 2001

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1-3/4"x4' Hand Bailer	1/2	0	1

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 49 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch. 80 PVC	0	49

Perforations:
Type perforation Factory
Size perforation 0.020 Slotted Screen
From 25 feet to 49 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 10 ft.
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
10'-17' Grout - pumped
17'-23' Bentonite Pellets
Gravel Packed: [X] Yes [ ] No Silica sand 10/20
From 23 feet to 50 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Rick Jones By Gerald D. Christiansen
(By driller performing actual drilling on site or contractor)
Date December 10, 2001