WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85302
Permit No.
Basin 207

NOTICE OF INTENT NO. 45799

1. OWNER Nevada Dept. of Transportation
MAILING ADDRESS 1263 South Stewart Street
Carson City, Nevada 89712

ADDRESS AT WELL LOCATION 29.5 Miles South of Lund M.P. 21 SR 318

2. LOCATION SW ¼ NE ¼ Sec. 21 T. 7 N/S R. 62 E. Nye County

Waiver ~~PERMIT NO.~~ M/O - 1226 (Issued by Water Resources) | N/A (Parcel No.) | Hole No. 1 of 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ■ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
■ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvial gravel & boulders		0	5	5
Gravelly sand & silt		5	15	10
Clay & gravel		15	23	8
Gravel & sand		23	28	5
Brown clay		28	32	4
Clay & gravel		32	40	8
Clay & gravel with	X	40		
water bearing stringers			45	5
Silty clay		45	80	35

Date started October 22, 19 2001
Date completed October 23, 19 2001

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1 3/4"x4' Hand Bailer	1/2	0	1

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	80 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch. 80 PVC	0	55

Perforations:
Type perforation Factory
Size perforation 0.020 Slotted Screen
From 30 feet to 55 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10 Ft.
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
Silica Sand 10/20
From 27 feet to 56 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout
10'-23' Grout - pumped
23'-27' Bentonite pellet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Rich Lewis By Jerald D. Christiansen
(By driller performing actual drilling on site or contractor)
Date December 10, 2001