WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85303
Permit No.
Basin 103

NOTICE OF INTENT NO. 42226

1. OWNER R & B Developement
MAILING ADDRESS 1380 Greg St. Suite #230
Sparks, NV 89431

ADDRESS AT WELL LOCATION 200' East of the corner of Cardelli Lane and Rive Road

2. LOCATION SW 1/4 SW 1/4 Sec. 33 T 17N N/S R 22 E Lyon County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level at a deoth of 31'. Measured well depth at a depth of 220'. Installed bailer and bailed well until we hit a hard bottom at 240'. Installed Mill Knife perforator and perforated 6 rows per foot from 220' up to 50' where perforator would not cut casing. Installed 230' of 2" tremme pipe and pumped in 7 cubic yards of neat cement. Well volume should have only required 4.1 yards. (no original log found on well)				

RECEIVED 01 DEC 10 PM 2:03 STATE ENGINEER'S OFFICE

Date started 12/3/01 , 19__
Date completed 12/4/2001 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
	Inches		Feet		Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.188	+1	240'

Perforations:
Type perforation Mills Knife
Size perforation
From 50' feet to 240' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 240'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 31' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Stromp
By driller performing actual drilling on-site or contractor
Date 12/7/01

USE ADDITIONAL SHEETS IF NECESSARY