WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85312
Permit No.
Basin 82

NOTICE OF INTENT NO. 4645

1. OWNER DRI 1000 Dailey Rd ms 186
MAILING ADDRESS Reno NV 89512
ADDRESS AT WELL LOCATION 362 Hill Ranch Rd Wadsworth NV 89442

2. LOCATION NE ¼ SE ¼ Sec. 22 T. 21 N/S R. 24 E. ~~Storey~~ Washoe County
PERMIT NO. ____ Issued by Water Resources | Parcel No. Wadsworth | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Hand Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| gravels / cobbles | 8 | 0 | 20 | |

Date started 9/1/01, 19____
Date completed 9/1/01, 19____

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 8 | 0 | 20 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | Factory | 0.20 | 0 | 20 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory
Size perforation 0.20
From 10 feet to 20 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From 10 feet to 20 feet

9. WATER LEVEL
Static water level 7 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling (Contractor)
Address 1635 Bellford Rd 89509 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2139
Signed ____ (By driller performing actual drilling on site or contractor)
Date 9/27/01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627