

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 7186

1. OWNER Paul Grease ADDRESS AT WELL LOCATION 2980 Washoe Valley Rd  
 MAILING ADDRESS 2185 White Pine Drive Washoe Valley 92310 Washoe Valley 92630  
 2. LOCATION NE 1/4 Sec 31 T 17 N S R 20 E Washoe County  
 PERMIT NO. WLC 10225 Issued by Water Resources 05-0-106-05 Parcel No. Washoe City Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>25</u>	<u>25'</u>
<u>Clay + gravel</u>		<u>25</u>	<u>75</u>	<u>50'</u>
<u>Sand + gravel</u>		<u>75</u>	<u>125</u>	<u>50'</u>
<u>gray clay</u>		<u>125</u>	<u>150</u>	<u>25'</u>
<u>granite</u>	<input checked="" type="checkbox"/>	<u>150</u>	<u>175</u>	<u>25</u>
<u>Gravel + sand</u>	<input checked="" type="checkbox"/>	<u>175</u>	<u>200</u>	<u>25</u>

8. WELL CONSTRUCTION  
 Depth Drilled 200' Feet Depth Cased 200' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>14</u>	<u>1.88</u>	<u>+1</u>	<u>200</u>

Perforations:  
 Type perforation jetting milled  
 Size perforation 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

Date started 11-19-01 11:49  
 Date completed 11-30-01 19

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>10'</u>	<u>1 1/2 hrs</u>

9. WATER LEVEL  
 Static water level 70 feet below land surface  
 Artesian flow WT G.P.M. 0.1 P.S.I.  
 Water temperature COLD °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name As H Pump Company Contractor  
 Address 15 Robert Drive Reno Nevada 89523 Contractor  
 Nevada contractor's license number 31539 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1378  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12-31-01