


REPORT NO. A01.066

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



NOTICE OF INTENT NO. 47312

OWNER RAY & MARY JO MADOLE ADDRESS OF WELL 3780 LYON LANE
MAILING ADDRESS 3780 LYON LANE, CARSON CITY, NV 89704 CARSON CITY, NV 89704
2. WELL LOCATION SE 1/4 SW 1/4 SEC. 6 T 16N R 20 E WASHOE COUNTY
PERMIT NO. _____ PARCEL NO. 050-482-18 SUBDIVISION NAME _____

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
DIRT & SAND		0	4	4
DG & SAND		4	18	14
B & W DG & BLACK CLAY		18	33	15
BLACK CLAY		33	50	17
GRAY CLAY		50	70	20
DG, BLUE-GRAY CLAY & ROCK		70	200	130
BLACK-GRAY CLAY, SOME SAND		200	220	20
GREEN, BLACK & GRAY CLAY		220	240	20
LIGHT GRAY CLAY, WHITE SAND		240	270	30
HARD GRANITE & GRAVELS	X	270	280	10

8. WELL CONSTRUCTION

Depth Drilled 280 Depth Cased 280
HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 260 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	+2	280

PERFORATIONS:

Type Perforation FACTORY Size Perforation 3/32 X 3
From 254 Feet to 274 Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL:

Yes No SEAL TYPE:
 Neat Cement

Seal Depth 240

PLACEMENT METHOD:

Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED:

Yes No

From 240 Feet to 280 Feet

9. WATER LEVEL

Static Water Level 3' Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature WARM F Quality CLEAR

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SVC., INC.

Address 675 EDISON WAY

RENO, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed [Signature]
By driller performing actual drilling on site or contractor

Dated Oct 3 - 2001

7. WELL TEST DATA

TEST METHOD Baller Pump Air Develop

TEST METHOD	GPM	DRAWDOWN	TIME (HRS)
	<u>20+</u>		<u>1 HR.</u>

Notes :

Date Started 09/24/01 Date Completed 09/26/01