

OFFICE USE ONLY  
 Log No. 85335  
 Permit No. 99  
 Basin. 7

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44313

1. OWNER Larry Garrett ADDRESS AT WELL LOCATION 16420 Dry Valley Rd Reno NV 89506  
 MAILING ADDRESS 260 Parr Blvd Reno NV 89512  
 2. LOCATION NE 1/4 NE 1/4 Sec 2 T 23 S R 18 E Washoe County Sierra  
 PERMIT NO. 078-263-33 Issued by Water Resources Parcel No. Sierra Rancho Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
DL (soft)		2	125	123
DL (Hard)		125	230	105
DL (beac)	x	230	265	35

8. WELL CONSTRUCTION  
 Depth Drilled 265 Feet Depth Cased 265 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 265 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.99	1.88	265	225
6 5/8	17.02	2.50	225	+2

Perforations:  
 Type perforation Saw slot  
 Size perforation 3/16 x 3.5  
 From 265 feet to 225 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 52  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 52 feet to 265 feet

Date started 12/1/01  
 Date completed 12/7/01

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	NA	4

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature Good °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Olencki Drilling & Pump Contractor  
 Address 15045 Red Rock Rd Reno NV 89506 Contractor  
 Nevada contractor's license number 50343 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656  
 Signed John F. Olencki  
 By driller performing actual drilling on site or contractor  
 Date 12/11/01