

OFFICE USE ONLY
 Log No. 35351
 Permit No. _____
 Basin 06

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45725

1. OWNER Ralph Douglas ADDRESS AT WELL LOCATION 3453 Grand Kan Way
 MAILING ADDRESS 1317 Jacobson Ln Wellington, NV 89444
 2. LOCATION 12.5E. SW 1/4 Sec. 14 T. 10 N. S. R. 22 E. Douglas County
 PERMIT NO. 1022-10-003-2978 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown D. Gr.		0	5	5
Brown Sand + River Rock		5	13	10
GRAVEL		13	30	15
BROWN CLAY		30	36	6
BROWN SAND + GRAVEL		36	60	24
BROWN CLAY		60	63	3
Red CLAY + GRAVEL		63	75	10
BROWN CLAY		75	78	3
BROWN SAND + GRAVEL		78	130	52
BLACK + GREEN + WHITE ROCK		130	140	10

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>		<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY
 Size perforation 3/32"
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 20 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 34 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started NOV. 3, 2001 19_____
 Date completed NOV. 3, 2001 19_____
 7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20-30</u>	<u>120</u>	<u>2 HRS.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump & Drilling
P.O. Box 2227
 Address Dayton, NV 89403
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
 Signed Thomas Evans
 By driller performing actual drilling on site or contractor
 Date NOV. 7, 2001