

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17275

1. OWNER Rod Winde ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SE 1/4 Sec. 23 T 20 N/S R. 25 E Lyon County
 PERMIT NO. 21-351-04 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		1	2	
Concretes		2	46	
Clay		46	63	
Gravels		63	98	
Clay		98	133	
Gravels	X	133	135	
Clay		135	173	

01 JUL 25 AM 11:30
 173 FEET TO SURFACE

8. WELL CONSTRUCTION
 Depth Drilled 173 Feet Depth Cased 173 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 173 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>20</u>
<u>6 5/8</u>	<u>PVC</u>	<u>40</u>	<u>20</u>	<u>173</u>

Perforations:
 Type perforation Machine Perf
 Size perforation 3/16 x 4 x 4 HOLES
 From 120 feet to 138 feet
 From 169 feet to 172 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 110' feet to 172 feet

9. WATER LEVEL
 Static water level 71 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature C °F Quality Good

Date started 6/27/01, 19____
 Date completed 6/28/01, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>12</u>	<u>2 1/4</u>	<u>-</u>
<u>how press static</u>			
<u>estimate up to 25 gpm possible</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Genan J. Drilling Inc Contractor
 Address PO 599 Contractor
S.S. NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 0097841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 6/27/01

