WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85364
Permit No.
Basin 91

NOTICE OF INTENT NO. 48217

1. OWNER Somersett Development DR-2
MAILING ADDRESS 100 W. Liberty Street, Suite 990
Reno, NV 89501

ADDRESS AT WELL LOCATION Somersett Project,
Washoe County, NV.

2. LOCATION NE 1/4 SW 1/4 Sec. 2 T 19N N/S R 18E E Washoe County
PERMIT NO. W-526-F (Issued by Water Resources) 38-360-36 (Parcel No.) Somersett (Subdivision Name)

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Casing was used only during drilling and was pulled as part of the abandonment.				
Abandoned by pumping abantonite through the rods while tripping out, poured hole plug and capped with 10' of neat cement.				
Quantities Used:				
Cement: 3.5 cu.ft.				
Hole plug: 1.4 cu.ft.				
Abantonite: 290 cu.ft.				

Date started 12/10/2001, 19__
Date completed 12/16/2001, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled ____ Feet Depth Cased 42 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7.875	Inches	0	Feet	40	Feet
5.875	Inches	40	Feet	1040	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.9	0.188	0	42

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. **WATER LEVEL**
Static water level 120 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1716
Signed David Haas (By driller performing actual drilling on-site or contractor)
Date 12/18/01

USE ADDITIONAL SHEETS IF NECESSARY

BST. C