

OFFICE USE ONLY
 Log No. 8537B
 Permit No. 68047T
 Basin 072

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46612

1. OWNER Tim Delona ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Box 367 Imly NV 89418
 2. LOCATION NE 1/4 NE 1/4 Sec. 23 T 33 N 34 E Pershing County
 PERMIT NO. 68047T Issued by Water Resources Parcel No. 08-150-52 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Topsoil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Clay</u>		<u>5</u>	<u>45</u>	<u>40</u>
<u>Sand</u>		<u>45</u>	<u>60</u>	<u>15</u>
<u>Blue Clay</u>		<u>60</u>	<u>80</u>	<u>20</u>
<u>Sand & Gravel</u>	<u>yes</u>	<u>80</u>	<u>95</u>	<u>15</u>
<u>Sand & Gravel</u>	<u>yes</u>	<u>95</u>	<u>110</u>	<u>10'</u>

8. WELL CONSTRUCTION
 Depth Drilled 110' Feet Depth Cased 95' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 95 Feet
5" Inches 95 Feet 110 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>10</u>	<u>1 3/8</u>	<u>1</u>	<u>95</u>

 Perforations:
 Type perforation Factory cut
 Size perforation 3/32 x 1/4
 From 75 feet to 95 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 95 feet

Date started Dec 3 2001
 Date completed Dec 5 2001

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			<u>4</u>

9. WATER LEVEL
 Static water level 50' feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature Low °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling Contractor
 Address 10760 Grass Valley Rd Contractor
Wim NV 89418
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed Chris Klumb
 By driller performing actual drilling on site or contractor
 Date Dec 26 01