WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85.384
Permit No.
Basin 101

NOTICE OF INTENT NO. 4656

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5770 SARAH

2. LOCATION SE 1/4 SW 1/4 Sec. 17 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. (Issued by Water Resources) 8-172-35 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
BROWN SAND		1	15	14
BROWN CLAY		15	18	3
BROWN SAND		18	30	12
BROWN CLAY		30	31	1
GRAY SAND		31	60	29
GREY CLAY		60	70	10
GREY SAND		70	85	15
BROWN CLAY		85	90	5
BROWN SAND	X	90	100	10

Date started 12/18/2001, 19__
Date completed 12/21/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN	20		1 HR

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	100	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	100

Perforations:
Type perforation MACHINE PERFFED
Size perforation .080
From 93 feet to 98 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 12'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSDCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed (By driller performing actual drilling on-site or contractor)
Date 1/10/2002

USE ADDITIONAL SHEETS IF NECESSARY