

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 85371
 Permit No. _____
 Basin 89
 NOTICE OF INTENT NO. 4627
2040 EASTLAKE BLVD
NEW WASHOE CITY, NV 89703

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **JOHN DANIELS**
 MAILING ADDRESS #7 RAGLAN CIR
CARSON CITY, NV 89701
 ADDRESS AT WELL LOCATION 2040 EASTLAKE BLVD
NEW WASHOE CITY, NV 89703

2. LOCATION NE 1/4 NE 1/4 Sec 31 T 17 N R 20 E **WASHOE** County
 PERMIT NO. 50-361-11
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLOW SANDS		0	8	8
COURSE DG SANDS		8	63	55
FRACTURED DG SAND		63	115	52
HARD DG GRANITE	X	115	163	48
BLUE GRANITE (HARD)	X	163	300	137

8. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 3/4</u> Inches	<u>0</u> Feet <u>300</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:

Type perforation **FACTORY MILL SLOT**
 Size perforation **3X 3/32**

From	To
<u>140</u> feet to <u>160</u> feet	
<u>280</u> feet to <u>300</u> feet	
_____ feet to _____ feet	
_____ feet to _____ feet	
_____ feet to _____ feet	

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 300 feet

Date started 7/30, 20 01
 Date completed 8/7, 20 01

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>7-9</u>	<u>95</u>	<u>3 HRS</u>

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. 7-9 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **CAPITAL CITY WELL DRILLING**
(CONTRACTOR)
 Address **20 KIT KAT DRIVE**
(CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Hawk
 By driller performing actual drilling on site or contractor
 Date 8/10/01