

OFFICE USE ONLY
 Log No. 85394
 Permit No. _____
 Basin 103


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45927

1. OWNER Sharon Anderson ADDRESS AT WELL LOCATION
 MAILING ADDRESS 375 Imperial Rd 375 Imperial Rd
Dayton, Nev 89403 DAYTON, NEV 89403
 2. LOCATION NE 1/4 SE 1/4 Sec. 4 T. 16 N/S R. 22 E LYON County
 PERMIT NO. 019-132-08 Dayton Valley Ranches Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	10	10
Brown Clay		10	33	23
Redish Brown Sand				
+ Gravel		33	70	37
Brown Clay		70	80	10
Brown Sand		80	105	25
Brown Clay		105	110	5
Redish Brown Sand				
+ Gravel		110	160	50
Brown + Grey Clay		160	169	9
Brown + Grey Sand		169	175	6
Lite Brown Clay		175	190	15
Large Sand and Small Gravel		190	260	70

RECEIVED
 FEB 11 11 08 AM
 DIVISION OF WATER RESOURCES

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
13 5/8 Inches 0 Feet 50 Feet
12 7/8 Inches 50 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>3 5/8</u>		<u>.188</u>	<u>+2</u>	<u>200</u>

Perforations:
 Type perforation 2/32 mill slot
 Size perforation _____
 From 200 feet to 260 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 260 feet

9. WATER LEVEL
 Static water level 63 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 1-3-02
 Date completed 1-6-02

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Airlift</u>	<u>200+</u>	<u>200</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump + Drilling Contractor
 Address PO Box 2227 Contractor
Dayton, Nev 89403
 Nevada contractor's license number issued by the State Contractor's Board 0046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
 Signed Monty Kow
 By driller performing actual drilling on site or contractor
 Date 1-15-02