

OFFICE USE ONLY  
 Log No. 85402  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47012

1. OWNER Sheila Byington ADDRESS AT WELL LOCATION 1155 Centerville Dr  
 MAILING ADDRESS 1155 Centerville Dr  
Bardnerville, NV 89410 Bardnerville, NV  
 2. LOCATION SE 1/4 SE 1/4 Sec. 8 T. 12 N. R. 20 E. Douglas County  
 PERMIT NO. 27120138 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SOIL, SAND</u>		<u>0</u>	<u>40</u>	<u>40</u>
<u>COBBLES</u>				
<u>SAND, small gravel</u>	<u>70+</u>	<u>40</u>	<u>222</u>	<u>182</u>

8. WELL CONSTRUCTION  
 Depth Drilled 222 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 222 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>41</u>	<u>160</u>

Perforations:  
 Type perforation factory cut  
 Size perforation 3/32 x 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 222 feet

9. WATER LEVEL  
 Static water level 49' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

Date started 10-1 01, 19\_\_\_\_  
 Date completed 10-5 01, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>80+</u>		<u>2 hours</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sierra Nevada Drilling & Pumping Contractor  
 Address 3540 Greenacres Dr Carson  
City NV 89105 Contractor  
 Nevada contractor's license number 52078  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1902  
 Division of Water Resources, the on-site driller.  
 Signed John S. David  
 By driller performing actual drilling on site or contractor  
 Date 10-6-01

RECEIVED  
 01 OCT 18 AM 11:28  
 STATE ENGINEERING OFFICE