

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42108

1. OWNER Tom + Lynn Avant ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 951 Riverview _____
Bardnerville, NV 89410 _____
 2. LOCATION NW 1/4 NE 1/4 Sec. 15 T. 12 N. R. 20 E. Douglas County
 PERMIT NO. 122015510009 Parcel No. _____
 Issued by Water Resources _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Fill</u>		<u>130</u>	<u>030</u>	<u>30</u>
<u>COBBLES, SAND, GRAVEL</u>		<u>30</u>	<u>305</u>	<u>275</u>

RECEIVED
 01 OCT 18 AM 11:28
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 305 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 305 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>200</u>
<u>6 5/8</u>		<u>.188</u>	<u>220</u>	<u>280</u>

Perforations:
 Type perforation factory cut
 Size perforation 3/32" x 3"
 From 200 feet to 220 feet
 From 280 feet to 300 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 300 feet

9. WATER LEVEL
 Static water level 109 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 9-26 01 19
 Date completed 9-30 01 19

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60-70</u>	<u>+</u>	<u>2 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nevada Drilling + Pumping Contractor
 Address 3540 Green Acres Dr. Carson City Contractor
NV 89705
 Nevada contractor's license number issued by the State Contractor's Board 52078
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
 Signed John S. Storch
 By driller performing actual drilling on site or contractor
 Date 10-6-01