WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85405
Permit No.
Basin 69

NOTICE OF INTENT NO.

1. OWNER Winnemucca Farms Inc.
MAILING ADDRESS PO Box 2130
Winnemucca NV 89445
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec 12 T 37 N/S R 39 E/W Humboldt County
PERMIT NO.: 65828, 65829, 65830 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Reverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top Soil		0	10	
hard Pan		10	11	
Burnt Clay w/Sand		11	43	
Sand & Small gravel		43	52	
Burnt Clay		52	53	
Coarse Sand w/Clay mix		53	69	
Sand, Gravel, Clay		69	184	
Coarse Sand		184	201	
Burnt Clay		201	205	
Coarse Sand & Gravel		205	234	
Sand & Gravel		234	254	
Broken Basalt &		254	344	
hard Burnt Clay				
white Clay & Sand		344	350	
Sand Stone & Clay		350	370	
Silt Stone Clay, Gravel		370	445	
Coarse Sand small gravel		445	455	
tan Clay & Silt Stone		455	470	
Sandy Clay & Gravel		470	490	
Gravel & Clay		490	512	
tan Clay		512	525	
Gravel & Clay		525	570	
Sand, Gravel, Clay		570	597	
blue Clay Sand		597	632	
Gravel mix				
Gravel Sand, Clay		632	660	

Date started 9-17, 2001
Date completed 11-30-, 2001

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2450 gal	2.08'	24 HRS

8. WELL CONSTRUCTION
Depth Drilled 660' Feet Depth Cased 660' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
28"	0	660

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18"		.375	+2	200
18"		.375	320	440
18"		.375	620	660

Perforations:
Type perforation Johnson Wire Wrap
Size perforation .035
From 200 feet to 320 feet
From 440 feet to 620 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50' feet to 660' feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Good.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Riverside Inc. Contractor
Address P.O. Box 220 Contractor
Parma Id.
Nevada contractor's license number issued by the State Contractor's Board 0044980
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2110
Signed [signature] By driller performing actual drilling on site or contractor
Date 12-19-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627