

OFFICE USE ONLY  
 Log No. 85412  
 Permit No. \_\_\_\_\_  
 Basin. 230  
 NOTICE OF INTENT NO. 21672

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Ron & Lorraine Selbach ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 269 Tamarack St.  
Amarogosa Valley, NV. 89020 Amarogosa Valley, NV. 89020  
 2. LOCATION SE 1/4 NW 1/4 Sec. 15 T. 16 N. R. 048 E. County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. 19-741-04 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other Mid

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Snd		0	55	55
Snd & gravel		55	60	5
tan sily.		60	69	9
Snd		68	95	27
large gravel		95	99	4
brown cly.		99	112	13
Snd		112	118	6
Snd & gravel	1st	118	130	12
Snd		130	162	32
Limestone		162	167	5
gravel & cly	2nd	167	175	8
gravel w/ shd.		175	198	23
Bottom of Well				198

8. WELL CONSTRUCTION  
 Depth Drilled 198 Feet Depth Cased 198 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches To 198 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	Steel	.250	0	198

 Perforations:  
 Type perforation Machined  
 Size perforation 3/16" X 3" every 12"  
 From 118 feet to 138 feet  
 From 158 feet to 198 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50'  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 198 feet

Date started 1-09-2002, 19\_\_\_\_\_  
 Date completed 1-12-2002, 19\_\_\_\_\_  
 7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name Cook Drilling Co.  
 Address HCR 70 Box 543  
Amarogosa Valley, NV 89020  
 Nevada contractor's license number issued by the State Contractor's Board 5376-A  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 2160  
 Signed Ron Selbach  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_