WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85420
Permit No.
Basin 163

NOTICE OF INTENT NO. 22731

1. OWNER THOMAS MADRIL
MAILING ADDRESS
ADDRESS AT WELL LOCATION 420 W ONYX AVE ONYX AV. + TRAILING ROSE ST. SANDY VALLEY NV.

2. LOCATION NE¼/NW¼ SW¼/NE¼ Sec. 36 T. 24 N/S R. 56 E. CLARK County
PERMIT NO. Issued by Water Resources 200-36-601-004 Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	3	3
SANDY LOAM		3	8	5
CLAY		8	28	20
CALICHIE		28	32	4
CLAY		32	53	21
CALICHIE		53	58	5
CLAY		58	74	16
CALICHIE	W.B.	74	78	4
CLAY		78	90	12
CALICHIE	W.B	90	95	5
CLAY		95	115	20
CALICHIE	W.B	115	122	7
CLAY		122	132	10
CALICHIE	W.B	132	138	6
CLAY		138	140	2

DCNR/DWR RECEIVED FEB 11 2002 LAS VEGAS OFFICE

Date started 1-3 2002
Date completed 1-5 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.33	.316	0	140

Perforations:
Type perforation FACTORY SCREEN
Size perforation 1/8 INCH BY 3 INCH
From 140 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 FT.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO Contractor
Address P.O. BOX 3505 Contractor
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
Signed By driller performing actual drilling on site or contractor
Date 1-5-2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627