

Log No. 655421
Permit No. 212
Basin

WELL DRILLER'S REPORT

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21249

1. OWNER NAME AND MAILING ADDRESS: MR AND MRS QUINCY R. BENTLEY, 316 S. DELAWARE BLVD, LAS VEGAS, NV 89107

2. LOCATION: SE 1/4, NE 1/4 Sec 36, T. 20 N, R. 60 E, CLARK COUNTY

PERMIT NO. 188-36-601-003 Parcel No. 20 N 0 R 60 E CLARK Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE: Domestic Municipal/Industrial Irrigation Test Monitor Stock Air Other

5. WELL TYPE: SW-1 Cable Rotary RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ASPHALT</u>		<u>0</u>	<u>1</u>	<u>1</u>
<u>SILTY SAND WITH GRAVEL</u>		<u>1</u>	<u>9</u>	<u>8</u>
<u>CLAYE</u>		<u>9</u>	<u>10</u>	<u>1</u>
<u>SILTY SAND</u>		<u>10</u>	<u>20</u>	<u>10</u>

8. WELL CONSTRUCTION

Depth Drilled: 20 Feet Depth Cased: 20 Feet

HOLE DIAMETER (BIT SIZE)

5 1/2 Inches From 0 Feet To 20 Feet

Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>0.308</u>		

Perforations:

Type perforation: FRZYLY SLT MC

Size perforation: 0.070 IN

From 10 feet to 20 feet

From feet to feet

From feet to feet

From feet to feet

From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement Cement GROUT Concrete GROUT

Depth of Seal: 5

Placement Method: Pumped Poured

Gravel Packed: Yes No

From 5 feet to 20 feet

9. WATER LEVEL

Static water level: 12 feet below land surface

Artesian flow G.P.M. P.S.I.

Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: CONVERSE CONSULTANTS

Contractor: H

Address: 731 PILOT ROAD LAS VEGAS, NV 89119

Nevada contractor's license number 418947

issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: W-1589

Signed: Heinrich J. Adams

By driller performing actual drilling on site or contractor

Date:

7. WELL TEST DATA

Date started: 9/7/01

Date completed: 9/7/01

TEST METHOD: Bailor Pump Air Lift

G.P.M. (Feet Below Static) Time (Hours)