

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21249

1. OWNER WADSWORTH PARTNERS  
MAILING ADDRESS: 1000 GLENDON AVENUE #1200  
LAS VEGAS, NV 89024  
ADDRESS AT WELL LOCATION: 316 S DUCAZAR BLVD  
LAS VEGAS, NV 89107  
2. LOCATION SE 1/4 NE 1/4 Sec. 36 T. 20 N. 36 E. 60 E County CLARK  
PERMIT NO. 138-36-601-003 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  
 Deepen  Abandon  Other \_\_\_\_\_  Municipal/Industrial  Irrigation  Test  Cable  Rotary  RVC  
 Monitor  Stock  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ASPHALT</u>		<u>0</u>	<u>0.5</u>	<u>0.5</u>
<u>SANDY CLAY WITH</u>				
<u>GRAVEL</u>		<u>0.5</u>	<u>17</u>	<u>16.5</u>
<u>GRAVEL</u>		<u>17</u>	<u>21</u>	<u>4</u>
<u>SANDY CLAY WITH</u>				
<u>GRAVEL</u>		<u>21</u>	<u>23</u>	<u>2</u>
<u>GRAVEL</u>		<u>23</u>	<u>25</u>	<u>2</u>
<u>SANDY CLAY WITH</u>				
<u>GRAVEL</u>		<u>25</u>	<u>28</u>	<u>3</u>
<u>SANDY CLAY</u>		<u>28</u>	<u>37</u>	<u>9</u>

8. WELL CONSTRUCTION

Depth Drilled 37 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
5 1/2 Inches 37 Feet  
Inches \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>0.302</u>	<u>0</u>	<u>37</u>

Perforations:  
Type perforation FRACURE STRET AWL  
Size perforation 0.020  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal \_\_\_\_\_ Placement Method:  Pumped  Cement GROUT  
 Poured  Concrete GROUT  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 12 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the reports true to the best of my knowledge.

Name CONVERSE CONSTRUCTION  
Contractor  
Address: 731 OLIVE ROAD STE H  
LAS VEGAS, NV 89149  
Contractor

Nevada contractor's license number 48547  
issued by the State Contractor's Board.  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller WJSCB9  
Signed Wendell J. McPherson  
By driller performing actual drilling on site or contractor

7. WELL TEST DATA  
Date started 9/1/01 Date completed 9/1/01  
TEST METHOD:  Bailler  Pump  Air Lift  
G.P.M. \_\_\_\_\_ Draw Down (Feet Below Static) \_\_\_\_\_ Time (Hours) \_\_\_\_\_