

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 21249

OFFICE USE ONLY  
Log No. 85426  
Permit No. 012  
Basin

1. OWNER MADISON MAQUETTE PAVING SERVICES ADDRESS AT WELL LOCATION 316 S. DEBARGE BLVD.  
MAILING ADDRESS 1400 GLENDEN AVE STE 1200 LAS VEGAS, NV 89107  
2. LOCATION SE 1/4 NE 1/4 Sec 36T 20N08R 60E CLARK County  
PERMIT NO. 138-36-601-003 Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Test  Cable  Rotary  RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.5	0.5
SANDY CLAY		0.5	6	5.5
SANDY CLAY WITH GRAVEL		6	8	2
CLAYE		8	14	3
SANDY CLAY WITH GRAVEL		11	13	8
CLAYE		19	21	2
SANDY CLAY WITH GRAVEL		21	23	2
CLAYE		23	25	2
SANDY CLAY WITH GRAVEL		25	33	8
GRAVEL		33	38	5

PROPOSED USE  
 Irrigation  Test  Cable  Rotary  RVC  
 Monitor  Stock  Air  Other

8. WELL CONSTRUCTION  
Depth Drilled 38 Feet  
WELL CONSTRUCTION  
HOLE DIAMETER (BIT SIZE)  
From 5 1/2 inches. To 38 Feet  
Inches. Feet  
Inches. Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	38

Perforations:  
Type perforation FRILING START AVE  
Size perforation 0.020 IN.  
From 10 feet to 38 feet  
From        feet to        feet  
From        feet to        feet  
From        feet to        feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 5 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From        feet to 38 feet

9. WATER LEVEL  
Static water level 12 feet below land surface  
Artesian flow        G.P.M. P.S.I.  
Water temperature        °F Quality       

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name CONVERSE CONSULTANTS  
Contractor 731 DI07 ROAD STE 14  
Address LAS VEGAS, NV 89119

Nevada contractor's license number 48947  
issued by the State Contractor's Board  
Nevada driller's license number issued by the W-1589  
Division of Water Resources, the on-site driller

Signed Randy J. Nelson  
By driller performing actual drilling on site or contractor  
Date       

Date started 9/12/01  
Date completed 9/12/01

7. WELL TEST DATA  
TEST METHOD:  Bailer  Pump  Air Lift  
G.P.M. Draw Down (Feet Below Static) Time (Hours)