

85431  
 OFFICE USE ONLY  
 Log No. **85431**  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21249

1. OWNER MADISON MARQUETTE REAGAN SOLVIER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1100 GLENDON AVE #1200 316 S. DECATUR BLVD.  
LOS ANGELES, CA 90024 LAS VEGAS, NV 89107  
 2. LOCATION SE 1/4 NE 1/4 Sec 36 T. 20 N. R. 60 E. CLARK County \_\_\_\_\_  
 PERMIT NO. 138-36-601-003  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE SW11  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY WITH GRAVEL		0	8	8
CALCITE		8	10	2
SANDY CLAY WITH GRAVEL		10	14	4
SANDY CLAY		14	17	3
CALCITE		17	21	4
GRAVEL		21	24.5	3.5
SANDY GRAVEL		24.5	31.5	7
CLAY		31.5	34.5	3
CALCITE		34.5	37	2.5

DCN R/DWR RECEIVED  
 FEB 16 2000  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 37 Feet Depth Cased 37 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 5 1/2 Inches To 0 Feet 37 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>0.308</u>	<u>0</u>	<u>37</u>

Perforations:  
 Type perforation FULLY SPLIT PIC  
 Size perforation 0.020 IN.  
 From 10 feet to 37 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 5  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 5 feet to 37 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CONVERSE CONSULTANTS  
 Address 731 PILOT ROAD A  
LAS VEGAS, NV 89119  
 Nevada contractor's license number 4B947  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11-1589  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_

Date started 9-18-01 19\_\_\_\_  
 Date completed 9-18-01 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)