

OFFICE USE ONLY
 Log No. 85435
 Permit No. _____
 Basin 43-94

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.349

NOTICE OF INTENT NO. 47715

1. OWNER EDWIN RODRIGUEZ ADDRESS AND WELL LOCATION NOTE: Access from
 MAILING ADDRESS 15064 Red Rock Road 116 Cobalt Lane / 15571 Red Rock Road
Reno, Nevada 89506 Reno, Nevada 89506
 LOCATION SW NE NE 12 T 22N 19 18 E Washoe
 PERMIT NO. 079-381-11 Red Rock Estates #80 parcel 2
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill decomposed granite		0	1	1
Top soil		1	3	2
Rusty brown granite with clay streaks		3	13	10
Weathered granite with clay streaks		13	42	31
Weathered granite		42	115	73
White clay		115	116	1
Weathered granite		116	155	39
Gray hard granite		155	215	60
Clay streaks		215	216	1
Gray hard granite		216	304	88
Fracture (NO WATER)		304	341	37
Reddish brown granite		341	355	14
Gray granite		355	404	49
Rusty soft zone		404	405	1
Gray granite		405	588	183
Soft zone (NO WATER)		588	590	2
Gray granite		590	680	90
Fracture	X	680	686	6
Gray granite		686	715	29
Fracture	X	715	716	1
Gray granite		716	722	6

8. WELL CONSTRUCTION
 Depth Drilled 722 Feet Depth Cased 722 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
 8 5/8 Inches 50 Feet 722 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	722

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 676 feet to 716 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 722 feet

Date started January 14, 2002, 19____
 Date completed January 17, 2002, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		

9. WATER LEVEL
 Static water level 620 feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date January 19, 2002