

OFFICE USE ONLY
 Log No. 26437
 Permit No. _____
 Basin 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37855

1. OWNER SCOTT & LOIS JOHNSON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1510 Glendale Cir. Hidden Valley Drive & Loma Vista
Sparks, Nevada 89431 Reno, Nevada 89511
 2. LOCATION NE 1/4 NE 1/4 Sec. 34 T. 19N N/S R. 20 E Washoe County
 PERMIT NO. Letter Jan. 2, 2001 021-270-12 Hidden Valley Area
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay with boulders		1	17	16
Brown sandy clay some boulders & gravel		17	48	31
Brown sandy clay		48	69	21
Purple volcanic rock		69	146	77
Brown volcanic rock		146	171	25
Gray volcanic rock		171	176	5
Brown volcanic rock		176	204	28
Frcture	X	204	209	5
Gray volcanic rock		209	215	16
Fracture rock	X	215	230	15
Gray volcanic rock		230	260	30
Fracture	X	260	264	4
Gray volcanic rock		264	289	25
Fracture	X	289	291	2
Gray volcanic rock		291	297	6

8. WELL CONSTRUCTION
 Depth Drilled 297 Feet Depth Cased 297 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 297 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	297

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 251 feet to 291 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 297 feet
 9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature cold °F Quality clear

Date started January 23, 2002, 19_____
 Date completed January 24, 2002, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board.
 Nevada driller's license number 923 issued by the
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date January 24, 2002