

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 85445
 Permit No. _____
 Basin 105
 NOTICE OF INTENT NO. 46384
46384

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER PETE PEARSON CONSTRUCTION ADDRESS AT WELL LOCATION 983 FARRIER CIR
 MAILING ADDRESS 765 INDIAN TRAIL RD GARDNERVILLE, NV 894510

2. LOCATION NE 1/4 SW 1/4 Sec 13 T 12 N R 20 E DOUGLAS County
 PERMIT NO. 1220/13/801/037 RHUENSTROTH SUBDIVISION
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
HARDPAN CLAY		0	5	5
COURSE SANDS AND BROWN CLAY		5	16	9
COURSE GRAVELS		16	21	5
BROWN CLAY		21	136	115
COURSE VOLCANIC SANDS		136	186	50
BROWN CLAY		186	245	59
LARGE FRACTURED GRAVELS SOFT AREA	XXX	245	280	35

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 3/4 Inches 0 Feet 80 Feet
9 7/8 Inches 80 Feet 280 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>280</u>

Perforations:
 Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32
 From 260 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 280 feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING
(CONTRACTOR)
 Address 20 KIT KAT DRIVE
(CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael L. Hack
 By driller performing actual drilling on site or contractor
 Date 11/30/01

Date started 11/26, 20 01
 Date completed 11/30, 20 01

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>40</u>	<u>3 HRS</u>

RECEIVED
 01 DEC 20 PM 4:53
 DIVISION OF WATER RESOURCES