WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85452
Permit No.
Basin 105

NOTICE OF INTENT NO. 47247

1. OWNER Jeffery Pisciotta Builders
MAILING ADDRESS P.O. Box 336
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 949 Heavenly View
Gardnerville, NV.

2. LOCATION NE 1/4 NW 1/4 Sec. 17 T 12N N/S R 20E E Douglas County
PERMIT NO. (Issued by Water Resources) 1220-17-501-031 (Parcel No.) Heavenly View (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil and boulders	no	0	4	4
Unsorted large gravel	no	4	123	119
well sorted small	yes	123		
gravel			175	52

RECEIVED
01 DEC 17 PM 1:12
STATE ENGINEER'S OFFICE

Date started 12/7/2001, 19__
Date completed 12/11/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
+30		1 hr

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	175	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	175

Perforations:
Type perforation Factory milled
Size perforation 1/8 X 3 6 row
From 135 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50ft
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc. (Contractor)
Address 7780 Curry Road (Contractor)
Fallon, NV. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed (By driller performing actual drilling on-site or contractor)
Date 12/14/2001

USE ADDITIONAL SHEETS IF NECESSARY