

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 85492
Permit No. 212
Basin: 212

NOTICE OF INTENT NO. 21248

1. OWNER BECKER ENTERPRISES ADDRESS AT WELL LOCATION 550 S. DEBRAVE BLVD
MAILING ADDRESS 50 S. JAMES BLVD #100 LAS VEGAS, NV 89107
2. LOCATION NE 1/4 SE 1/4 36 T 20 N 0 R 60 E CLARK County CLARK
PERMIT NO. 138-36-701-014 Parcel No. 20 Subdivision Name CLARK

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. Domestic Municipal/Industrial
 Irrigation Test Monitor Stock Cable Rotary RVC Air Other

5. WELL TYPE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sandy clay</u>		<u>0</u>	<u>26</u>	

8. WELL CONSTRUCTION

Depth Drilled 26 Feet Depth Cased 26 Feet

HOLE DIAMETER (BIT SIZE)

5 1/2 Inches. From 0 Feet To 26 Feet

Inches. Feet. Feet. Feet.

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>0.308</u>	<u>0</u>	<u>26</u>

Perforations:
Type perforation Matrix slot PVC
Size perforation 0.020 in.
From 10 feet to 26 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 10
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 10 feet to 26 feet

9. WATER LEVEL
Static water level 12.3 feet below land surface
Artesian flow G.P.M.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CONVERSE CONSULTANTS
Contractor

Name CONVERSE CONSULTANTS
Address 731 PILOT ROAD STG A
LAS VEGAS, NV 89115
Contractor

Nevada contractor's license number 48947
issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller W-1589
Signed Donald H. Moore
by driller performing actual drilling on site of contractor

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M. (Feet Below Static) Time (Hours)