

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. L18814

1. OWNER Le Ray Dargree & DePhane BRIGHT ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7435 FALCON ROCK DR 890 E DERBY
LAS VEGAS NV PAHRUMP NV
 2. LOCATION NE 1/4 SE 1/4 Sec. 10 T. 21S N/S R. 53 E NYC County _____
 PERMIT NO. 44-255-15 44-255-15 PLANTATION ESTATES BS L6
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
WHITE CLAY		4	16	12
LITE BROWN CLAY		16	45	29
CALICHE FORMATION		45	61	6
BROWN CLAY		51	84	33
HARD LIMESTONE	X	84	90	6
BROWN CLAY	X	90	134	44
SOFT-HARD LIMESTONE		134	141	7
BROWN CLAY	X	141	160	19

DCNR/DWR
RECEIVED
MAR 6 2002
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17#</u>	<u>1.88</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation TOUCH & GO
 Size perforation 8" LONG X 3/8" WIDE
 From 120 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 68 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Well DRILLING Contractor
 Address 1000 W. BASIN RD Contractor
PAHRUMP NV 89060
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg By driller performing actual drilling on site or contractor
 Date 1-29-2002

Date started 1-24-2002, 19_____
 Date completed 1-26-2002, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>5</u>	<u>15 min</u>