

OFFICE-USE ONLY
 Log No. 85504
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18815

1. OWNER CHARLES NYBERG ADDRESS AT WELL LOCATION 1480 FERN ST
 MAILING ADDRESS 1060 W BASIN AVE PAHRUMP NV 89060
 LOCATION SW 1/4 SE 1/4 Sec. 8 T 20S N0R 15 E NYE County
 PERMIT NO. 36-041-36 Issued by Water Resources Parcel No. 36-041-36 Subdivision Name NONE

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SURFACE		0	4	4
Lite Brown Clay		4	42	38
HARD SPOT		42	47	5
SOFT BROWN Clay		47	92	45
HARD DALLING CLAY		92	101	9
SOFT BROWN Clay	X	101	122	21
BROWN Clay	X	122	153	31

8. WELL CONSTRUCTION
 Depth Drilled 153 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches 0 Feet 153 Feet
 To _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17#</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation TORCH CUT
 Size perforation 8" LONG X 3/8" WIDE
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 153 feet

9. WATER LEVEL
 Static water level 56 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 2-14-02, 19_____
 Date completed 2-15-02, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>5</u>	<u>15 MIN</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CHARLES Nyberg Wellrig Drilling Contractor
 Address 1060 W BASIN Rd Contractor
PAHRUMP NV 89060
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date 2-21-02