WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85514
Permit No.
Basin 168

NOTICE OF INTENT NO. 19150

1. OWNER Billy Kuhn
MAILING ADDRESS 1400 W. Tornado St Pahrump, NV
ADDRESS AT WELL LOCATION 1400 W. Tornado St Pahrump

2. LOCATION SW ¼ NE ¼ Sec. 32 T. 20 N OR S 53 E. Nye County
PERMIT NO. ~~[illegible]~~ Issued by Water Resources
Parcel No. 40-541-07 / 40-541-07
Subdivision Name Calvada Valley Unit 5

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0'	5'	5'
white clay		5'	15'	10'
caliche		15'	20'	5'
white clay		20'	45'	25'
caliche		45'	50'	5'
white clay		50'	75'	25'
brown clay		75'	100'	25'
caliche		100'	105'	5'
brown clay		105'	130'	25'
white clay		130'	140'	10'

DCNR/DWR
RECEIVED
FEB 04 2002
LAS VEGAS OFFICE

Date started Nov 15 2001
Date completed Nov 20 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	140

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 58' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Co. (Contractor)
Address 4191 S. Jackie St. Pahrump, NV 89048 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date Dec 2, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627